



Report No.:

Test Time: 2021-08-22 11:47

Luminaire Property

Luminaire Manufacturer:

Luminaire Description: RAD-S-CIS-3.5000.24.8

Luminous Length (mm): -53

Luminous Width (mm): -53

Luminous Height (mm): 70

Voltage: 24.0 V

Current: 0.130 A

Power: 3.11 W

Power Factor: 1.000

Photometric Results

CIE Class: Direct

Measurement Flux: 296.1 lm

Downward Ratio: 100%

Total Rated Lamp Lumens: 296.1 lm

Efficiency: 100%

Upward Ratio: 0%

Field Angle(C0/C180,C90/C270,C45/C225,C135/315): 19.1, 18.7, 18.8, 19.0

Beam Angle(C0/C180,C90/C270,C45/C225,C135/315): 9.4, 9.1, 9.2, 9.3

Luminaire Efficacy Rating (LER): 95.25

Central Intensity: 6588.42 cd


Max. Intensity: 6648.61 cd

Pos of Max. Intensity: H190 V1


S/MH(C0/C180): 0.16

S/MH(C90/C270): 0.16

Picture Of Luminaire



Luminous Intensity Distribution Curve



— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 10.0

Test Lab: Svet-lab

Test Type: TYPE C

Temperature:

Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0



Test Device: LSG-1700B

Distance: 9.600 m

Humidity:

Inspector:


Luminous Intensity Distribution Curve




C Plane (°):0.0-360.0: 10.0
 Test Lab: Svet-lab
 Test Type: TYPE C
 Temperature:
 Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
 Test Device: LSG-1700B
 Distance: 9.600 m
 Humidity:
 Inspector:

Luminous Intensity Distribution Curve(cd/klm)




Isocandela (rectangle)



Imax (100%): 6649 cd

(10%): 665 cd	(16%): 1064 cd
(25%): 1662 cd	(40%): 2659 cd
(63%): 4189 cd	(100%): 6649 cd

IsoLux Plot




Mounting Height: 10.0m Max Lux(100%): 66.5 lx

(1%): 0.7 lx	(2%): 1.3 lx
(5%): 3.3 lx	(10%): 6.6 lx
(20%): 13.3 lx	(50%): 33.2 lx
(100%): 66.5 lx	


C Plane (°):0.0-360.0: 10.0
 Test Lab: Svet-lab
 Test Type: TYPE C
 Temperature:
 Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
 Test Device: LSG-1700B
 Distance: 9.600 m
 Humidity:
 Inspector:

Illuminance at a Distance



Vertical IsoLux Plot




Lowest(m): 1.0m Highest(m): 11.0m Max Lux: 6588.4 lx

— (1%): 65.9 lx	— (2%): 131.8 lx
— (5%): 329.4 lx	— (10%): 658.8 lx
— (20%):1317.7 lx	— (50%):3294.2 lx
— (100%):6588.4 lx	



The Average Illuminance Effective Figure






UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
3H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
12H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
X=4H Y=2H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
3H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
12H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
X=8H Y=4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
12H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
X=12H Y=4H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
6H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
8H	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$	-1.\$
Variations with the observer position at spacings:										
S=1.0H	-1.\$/4.9					-1.\$/5.0				
S=1.5H	-1.\$/7.6					-1.\$/7.8				
S=2.0H	-1.\$/9.6					-1.\$/9.8				

Calculate in accordance with CIE Pub.117. The table is revised with 296lm ($8\log(F/F_0) = -4.2$).

FLUX DISTRIBUTION TABLE BASED ON THE IESNA LUMINAIRE CLASSIFICATION SYSTEM


	ZONE	LUMENS	% LAMP LUMENS
	FORWARD LIGHT	137	46.2
	FL (0°-30°)	127	43.0
	FM (30°-60°)	9	3.2
	FH (60°-80°)	0	0.0
	FVH (80°-90°)	0	0.0
	BACK LIGHT	159	53.8
	BL (0°-30°)	149	50.4
	BM (30°-60°)	10	3.4
	BH (60°-80°)	0	0.0
	BVH (80°-90°)	0	0.0
	UP LIGHT	0	0.0
	UL (90°-100°)	0	0.0
	UH (100°-180°)	0	0.0
	TRAPPED LIGHT	NA	NA

BUG(Backlight,Uplight,Glare) Rating Base On TM-15-07	
Asymmetrical Luminaire Types (Type I,II,III,IV)	B1 U0 G0
Quadrilateral Symmetrical Luminaire Types (Type V,Area Light)	B1 U0 G0

C Plane (°):0.0-360.0: 10.0
 Test Lab: Svet-lab
 Test Type: TYPE C
 Temperature:
 Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
 Test Device: LSG-1700B
 Distance: 9.600 m
 Humidity:
 Inspector:

LCS Graph



Back Light

Forward Light

Scale= MAX LCS%

Trapped Light:NA,NA



Zonal Lumen

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
0.0-1.0	6373.8	6.1	6.1	2.06	2.06
1.0-2.0	5961.0	17.1	23.2	5.78	7.84
2.0-3.0	5206.4	24.9	48.1	8.41	16.25
3.0-4.0	4292.4	28.7	76.9	9.71	25.96
4.0-5.0	3401.4	29.3	106.1	9.88	35.84
5.0-6.0	2562.4	26.9	133.0	9.10	44.94
6.0-7.0	1862.7	23.1	156.2	7.81	52.75
7.0-8.0	1333.6	19.1	175.3	6.45	59.20
8.0-9.0	933.7	15.1	190.4	5.11	64.31
9.0-10.0	660.2	11.9	202.3	4.04	68.34
10.0-11.0	473.2	9.5	211.8	3.19	71.54
11.0-12.0	346.9	7.6	219.4	2.56	74.10
12.0-13.0	266.8	6.3	225.7	2.14	76.24
13.0-14.0	210.2	5.4	231.1	1.82	78.06
14.0-15.0	170.7	4.7	235.8	1.58	79.64
15.0-16.0	143.5	4.2	240.0	1.42	81.06
16.0-17.0	123.3	3.8	243.8	1.30	82.36
17.0-18.0	108.2	3.6	247.4	1.20	83.56
18.0-19.0	95.9	3.3	250.7	1.13	84.69
19.0-20.0	85.9	3.1	253.9	1.06	85.75
20.0-21.0	77.7	3.0	256.9	1.01	86.76
21.0-22.0	70.1	2.8	259.7	0.95	87.71
22.0-23.0	63.3	2.7	262.3	0.90	88.61
23.0-24.0	57.0	2.5	264.8	0.84	89.45
24.0-25.0	51.3	2.3	267.2	0.79	90.24
25.0-26.0	46.2	2.2	269.3	0.74	90.97
26.0-27.0	41.3	2.0	271.4	0.68	91.66
27.0-28.0	36.8	1.9	273.2	0.63	92.29
28.0-29.0	32.8	1.7	274.9	0.58	92.87
29.0-30.0	29.2	1.6	276.5	0.53	93.40
30.0-31.0	26.1	1.5	278.0	0.49	93.89
31.0-32.0	23.4	1.3	279.3	0.45	94.34
32.0-33.0	21.1	1.2	280.6	0.42	94.76
33.0-34.0	19.3	1.2	281.7	0.39	95.16
34.0-35.0	17.8	1.1	282.8	0.37	95.53
35.0-36.0	16.7	1.1	283.9	0.36	95.89

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:




Zonal Lumen (Continue 1)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
36.0-37.0	15.9	1.0	284.9	0.35	96.24
37.0-38.0	15.1	1.0	285.9	0.34	96.58
38.0-39.0	14.2	1.0	286.9	0.33	96.91
39.0-40.0	13.3	0.9	287.8	0.31	97.22
40.0-41.0	12.2	0.9	288.7	0.29	97.51
41.0-42.0	11.2	0.8	289.5	0.27	97.79
42.0-43.0	10.1	0.8	290.3	0.25	98.04
43.0-44.0	9.1	0.7	291.0	0.23	98.27
44.0-45.0	8.2	0.6	291.6	0.21	98.49
45.0-46.0	7.3	0.6	292.2	0.19	98.68
46.0-47.0	6.5	0.5	292.7	0.17	98.85
47.0-48.0	5.7	0.5	293.1	0.16	99.01
48.0-49.0	5.1	0.4	293.6	0.14	99.15
49.0-50.0	4.6	0.4	293.9	0.13	99.28
50.0-51.0	4.2	0.4	294.3	0.12	99.40
51.0-52.0	3.7	0.3	294.6	0.11	99.51
52.0-53.0	3.3	0.3	294.9	0.10	99.61
53.0-54.0	2.9	0.3	295.2	0.09	99.69
54.0-55.0	2.4	0.2	295.4	0.07	99.77
55.0-56.0	2.0	0.2	295.6	0.06	99.83
56.0-57.0	1.7	0.2	295.7	0.05	99.88
57.0-58.0	1.3	0.1	295.8	0.04	99.92
58.0-59.0	1.0	0.1	295.9	0.03	99.96
59.0-60.0	0.7	0.1	296.0	0.02	99.98
60.0-61.0	0.4	0.0	296.0	0.01	99.99
61.0-62.0	0.2	0.0	296.1	0.01	100.00
62.0-63.0	0.1	0.0	296.1	0.00	100.00
63.0-64.0	0.0	0.0	296.1	0.00	100.00
64.0-65.0	0.0	0.0	296.1	0.00	100.00
65.0-66.0	0.0	0.0	296.1	0.00	100.00
66.0-67.0	0.0	0.0	296.1	0.00	100.00
67.0-68.0	0.0	0.0	296.1	0.00	100.00
68.0-69.0	0.0	0.0	296.1	0.00	100.00
69.0-70.0	0.0	0.0	296.1	0.00	100.00
70.0-71.0	0.0	0.0	296.1	0.00	100.00
71.0-72.0	0.0	0.0	296.1	0.00	100.00

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Zonal Lumen (Continue 2)

[illegible]

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table

Unit: cd

G\C	C0.0	C10.0	C20.0	C30.0	C40.0	C50.0	C60.0	C70.0	C80.0	C90.0
G0.0	6588.4	6508.1	6542.0	6465.2	6529.1	6453.4	6515.8	6453.1	6492.1	6435.2
G1.0	6089.8	5949.4	5984.6	5904.4	5935.1	5861.6	5941.4	5898.5	5995.6	5955.1
G2.0	5296.5	5156.7	5153.8	5058.6	5129.9	5044.8	5144.8	5098.2	5188.7	5191.0
G3.0	4269.0	4126.3	4158.8	4019.0	4127.6	3999.4	4093.7	4051.1	4189.7	4159.9
G4.0	3376.5	3250.1	3230.7	3145.5	3197.5	3123.5	3201.0	3128.1	3247.8	3230.7
G5.0	2579.8	2438.5	2450.9	2346.7	2419.4	2323.7	2384.2	2358.3	2458.6	2447.7
G6.0	1828.1	1714.9	1725.0	1643.5	1698.4	1621.5	1696.2	1647.1	1725.8	1718.7
G7.0	1294.5	1228.9	1239.3	1175.0	1196.1	1157.1	1194.4	1177.6	1237.6	1232.6
G8.0	923.7	833.5	868.5	809.3	852.6	795.8	850.5	796.7	866.4	835.4
G9.0	632.5	599.8	605.7	581.4	585.1	563.3	583.1	572.0	602.3	599.3
G10.0	462.7	440.5	437.3	421.4	429.1	415.0	427.8	414.3	441.2	439.9
G11.0	338.1	318.8	321.2	311.0	311.6	302.6	310.1	306.2	319.7	320.3
G12.0	258.1	248.4	249.4	240.4	242.8	237.0	242.4	237.3	248.7	250.1
G13.0	206.3	197.9	198.6	193.2	195.9	190.1	195.9	192.5	198.3	200.0
G14.0	165.0	161.8	161.3	158.0	159.6	156.0	158.9	157.0	161.1	162.6
G15.0	140.5	136.7	136.4	134.5	136.7	132.6	136.4	135.5	137.4	138.9
G16.0	119.8	116.6	118.2	115.9	116.9	115.3	116.3	116.8	119.3	120.0
G17.0	106.2	103.3	104.0	102.8	104.3	102.8	103.7	103.0	105.7	106.4
G18.0	94.1	93.1	92.9	92.4	93.8	92.1	93.4	93.1	95.1	95.6
G19.0	84.4	84.6	83.9	83.0	84.2	82.5	83.9	83.4	84.1	85.6
G20.0	76.9	77.2	75.7	75.2	76.2	75.0	76.2	75.7	76.4	77.4
G21.0	68.9	68.7	68.9	67.0	69.1	66.7	67.8	67.8	68.0	69.6
G22.0	61.0	60.7	61.4	60.9	62.9	60.3	61.5	61.0	61.4	62.4
G23.0	54.9	54.9	55.6	54.6	55.9	53.7	55.1	55.1	55.9	56.3
G24.0	49.4	48.9	49.1	49.4	50.6	48.6	49.3	49.4	50.3	50.5
G25.0	44.8	44.3	44.7	44.8	45.0	43.6	44.8	44.0	45.5	45.3
G26.0	39.9	39.7	39.9	39.7	41.3	38.7	40.4	39.9	40.9	40.4
G27.0	36.1	35.0	35.0	35.0	36.3	35.8	35.8	36.0	36.0	36.5
G28.0	32.2	31.2	31.2	31.5	32.4	31.5	31.9	31.9	32.6	32.6
G29.0	29.1	27.6	28.1	28.3	29.3	28.0	29.0	28.0	28.6	28.8
G30.0	26.3	25.2	25.1	25.6	26.4	25.9	24.9	24.9	25.2	25.7
G31.0	23.5	22.5	22.3	23.2	23.9	23.0	23.2	22.5	23.4	23.5
G32.0	21.1	20.5	20.1	21.3	21.5	20.8	20.6	20.5	20.8	21.3
G33.0	19.6	19.3	18.9	19.3	19.4	19.4	17.0	18.8	19.6	18.9
G34.0	18.2	18.1	17.4	18.1	18.4	18.2	15.7	17.0	18.4	17.7
G35.0	16.5	16.7	16.9	17.7	17.6	17.7	14.7	17.0	17.6	17.2
G36.0	16.0	16.4	15.7	16.7	17.0	16.2	14.3	16.2	17.2	16.2

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 1)

Unit: cd

G\C	C0.0	C10.0	C20.0	C30.0	C40.0	C50.0	C60.0	C70.0	C80.0	C90.0
G37.0	15.5	15.2	15.3	16.0	15.9	16.2	13.3	14.7	16.4	16.2
G38.0	14.5	13.8	14.1	14.5	14.8	14.7	12.4	14.7	15.0	15.2
G39.0	13.3	13.0	13.3	13.5	14.1	13.8	11.9	13.8	14.0	14.1
G40.0	12.6	11.6	12.3	12.4	11.9	11.1	11.1	13.0	13.0	11.4
G41.0	11.9	11.3	10.7	11.1	11.4	10.1	9.7	11.4	11.8	10.9
G42.0	10.6	10.1	9.9	10.6	10.7	8.9	8.7	10.2	10.7	8.9
G43.0	9.6	8.7	8.7	9.0	8.7	9.2	7.3	9.2	9.2	8.4
G44.0	8.7	7.8	8.2	8.7	8.2	9.0	6.7	8.4	8.4	7.2
G45.0	8.0	7.0	7.0	7.2	7.8	7.5	5.8	6.7	7.2	6.8
G46.0	7.2	6.1	6.1	6.7	7.2	6.7	4.9	7.0	6.0	5.8
G47.0	6.8	4.8	6.0	6.3	6.0	6.0	4.6	6.1	5.3	5.3
G48.0	5.1	5.5	4.8	5.1	4.8	5.1	3.8	5.6	4.6	4.3
G49.0	4.6	4.9	4.8	4.6	4.1	4.9	3.2	5.1	4.8	3.6
G50.0	4.3	4.1	4.3	4.9	3.9	4.1	3.1	4.9	4.6	2.9
G51.0	3.1	3.8	3.9	4.1	4.6	3.6	2.2	4.6	3.8	2.7
G52.0	4.3	3.1	3.1	3.8	3.9	3.2	2.2	4.1	3.6	2.2
G53.0	4.3	3.2	3.2	3.1	3.8	3.2	1.7	2.9	2.6	2.4
G54.0	3.1	2.4	2.4	2.7	3.1	2.2	0.9	2.9	2.0	1.7
G55.0	2.7	1.7	2.4	2.0	2.4	2.0	0.9	2.4	2.2	1.2
G56.0	2.6	1.5	1.9	2.0	1.9	1.9	0.2	2.4	2.0	0.2
G57.0	2.2	1.7	2.2	1.7	1.9	1.4	0.0	2.2	1.5	0.5
G58.0	1.4	1.5	1.5	1.5	1.2	1.0	0.0	1.4	1.4	0.0
G59.0	0.5	1.0	1.9	1.4	1.0	0.7	0.0	1.0	0.7	0.0
G60.0	0.5	0.5	0.7	0.2	0.0	0.5	0.0	0.3	0.2	0.0
G61.0	0.5	0.2	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0
G62.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G63.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 3)

Unit: cd

G\C	C100.0	C110.0	C120.0	C130.0	C140.0	C150.0	C160.0	C170.0	C180.0	C190.0
G0.0	6481.7	6452.7	6472.3	6462.4	6470.6	6489.0	6472.3	6514.1	6588.4	6508.1
G1.0	6067.3	6052.3	6166.8	6174.6	6299.5	6317.9	6417.4	6456.8	6625.6	6648.6
G2.0	5314.9	5350.0	5489.3	5549.6	5719.3	5778.3	5951.3	6001.6	6218.5	6302.4
G3.0	4338.5	4353.7	4551.6	4594.8	4836.3	4873.3	5121.4	5180.2	5420.4	5540.1
G4.0	3435.6	3418.9	3652.0	3701.1	3937.5	3987.5	4194.1	4255.1	4485.1	4652.4
G5.0	2588.1	2614.1	2784.4	2835.5	3045.4	3095.9	3279.1	3338.3	3580.9	3697.0
G6.0	1833.1	1857.9	2025.9	2070.9	2246.1	2255.2	2441.2	2486.2	2652.6	2754.2
G7.0	1322.6	1342.8	1455.8	1490.9	1630.7	1661.9	1812.9	1818.7	1977.1	2062.0
G8.0	929.0	915.3	1045.4	1021.0	1160.5	1163.4	1296.9	1279.2	1395.6	1483.2
G9.0	645.1	655.9	715.2	731.7	807.3	835.2	889.3	901.4	986.9	1032.5
G10.0	464.4	479.2	521.0	530.9	584.6	595.8	642.6	649.2	708.7	740.3
G11.0	340.0	345.9	371.1	383.6	413.8	428.6	457.6	455.5	494.4	513.7
G12.0	263.9	268.2	284.9	289.5	313.9	321.0	340.1	343.9	369.4	383.4
G13.0	209.7	212.9	224.4	227.1	242.6	249.3	264.3	263.6	280.6	293.9
G14.0	169.6	171.5	179.9	180.4	192.5	197.1	205.4	207.6	218.1	225.4
G15.0	143.0	145.6	150.9	150.9	159.1	162.5	169.6	169.3	177.3	185.1
G16.0	123.3	125.5	128.9	128.0	134.2	137.6	140.6	141.5	146.8	154.8
G17.0	109.1	110.8	112.3	111.3	117.3	119.7	121.9	122.4	126.7	131.3
G18.0	97.2	98.2	101.1	99.9	103.3	105.2	107.8	107.2	110.7	113.9
G19.0	87.5	88.3	89.8	88.8	92.1	93.3	96.2	94.8	96.3	100.3
G20.0	78.9	79.3	81.8	80.5	83.0	84.1	87.1	85.8	86.9	89.7
G21.0	70.8	71.3	73.3	72.5	75.5	75.5	78.9	77.2	78.9	82.2
G22.0	62.9	63.8	65.8	64.4	67.3	68.5	71.1	69.6	70.8	74.8
G23.0	57.1	57.8	58.8	58.1	61.0	61.2	64.1	62.6	64.1	67.7
G24.0	50.6	51.5	52.8	51.3	54.0	54.6	56.6	55.1	57.1	61.0
G25.0	46.7	46.7	47.9	46.7	48.8	49.8	51.3	49.8	50.6	54.2
G26.0	41.8	41.6	41.9	41.3	44.3	44.7	47.0	45.3	46.0	49.6
G27.0	37.0	36.8	37.0	36.7	38.7	39.5	41.6	39.9	39.9	44.2
G28.0	33.1	32.7	32.6	32.9	35.1	35.3	36.7	36.1	36.0	39.2
G29.0	29.3	29.1	28.6	28.1	30.7	31.9	33.2	31.4	32.4	35.1
G30.0	26.6	26.6	25.4	25.2	27.3	28.3	29.3	28.3	28.8	30.7
G31.0	24.2	23.4	22.2	22.9	23.9	25.4	26.4	24.7	25.6	27.5
G32.0	21.8	21.6	19.8	20.6	21.0	23.0	22.9	22.7	22.5	24.9
G33.0	19.6	19.1	17.9	18.8	19.1	20.6	21.5	20.5	20.0	22.5
G34.0	18.2	18.8	17.0	17.0	17.0	19.8	19.1	18.9	18.4	20.6
G35.0	17.0	17.2	15.7	16.7	15.7	17.9	18.1	17.4	18.4	18.1
G36.0	16.2	16.5	15.0	16.7	14.5	16.5	16.7	15.9	17.4	18.1

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:




Candlepower Table (Continue 4)

Unit: cd

G\C	C100.0	C110.0	C120.0	C130.0	C140.0	C150.0	C160.0	C170.0	C180.0	C190.0
G37.0	16.2	15.9	13.8	15.7	15.3	15.5	16.2	15.3	16.0	16.5
G38.0	14.7	14.5	13.1	15.2	13.8	14.8	15.5	14.8	15.3	16.0
G39.0	13.8	14.3	12.4	13.6	13.3	14.0	14.5	13.5	14.0	14.3
G40.0	13.6	13.0	11.4	13.5	12.4	13.1	13.3	13.5	14.0	14.0
G41.0	13.0	11.8	11.6	11.9	10.6	12.3	12.1	11.1	12.8	12.4
G42.0	11.6	10.9	10.7	11.3	9.0	10.7	11.4	10.9	11.6	11.9
G43.0	10.6	9.6	8.5	9.9	8.7	9.7	10.7	9.2	10.7	10.9
G44.0	9.9	8.9	7.8	8.5	7.2	9.0	9.4	8.7	9.4	9.2
G45.0	9.2	8.2	6.8	8.0	6.1	7.7	8.5	7.0	8.2	8.7
G46.0	8.0	7.5	7.5	6.8	4.9	7.3	8.2	6.0	7.8	7.7
G47.0	7.2	6.7	7.0	6.5	4.3	6.1	6.8	5.5	6.5	7.2
G48.0	6.1	5.5	6.3	5.3	4.1	5.5	6.0	5.3	6.0	6.3
G49.0	6.0	5.8	5.1	4.4	2.6	5.1	6.0	4.8	5.5	5.8
G50.0	6.0	4.9	5.5	3.9	2.9	4.9	5.3	4.1	4.6	5.1
G51.0	5.5	4.6	4.1	3.6	1.9	4.4	4.6	3.8	4.8	4.6
G52.0	4.3	1.7	3.9	3.2	2.4	4.1	5.1	3.4	3.9	4.3
G53.0	3.9	1.7	3.8	3.1	1.4	3.9	4.3	3.2	3.4	4.1
G54.0	3.1	1.4	3.2	2.2	0.9	3.9	3.6	2.7	2.9	3.2
G55.0	2.7	1.9	2.7	2.4	0.3	3.4	2.9	1.5	1.9	2.7
G56.0	2.4	0.7	2.6	1.7	0.5	2.4	2.4	0.7	1.9	2.9
G57.0	2.0	0.7	1.7	0.7	0.0	2.6	2.4	1.0	1.7	2.0
G58.0	2.2	0.2	1.2	0.5	0.0	1.9	1.5	0.5	1.5	1.4
G59.0	1.5	0.0	1.0	0.2	0.0	1.4	0.0	0.2	1.0	2.4
G60.0	1.2	0.0	0.3	0.0	0.0	0.9	0.5	0.0	0.2	1.2
G61.0	0.7	0.0	0.2	0.0	0.0	0.7	0.0	0.0	0.0	0.2
G62.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G63.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 6)

Unit: cd

G\C	C200.0	C210.0	C220.0	C230.0	C240.0	C250.0	C260.0	C270.0	C280.0	C290.0
G0.0	6542.0	6465.2	6529.1	6453.4	6515.8	6453.1	6492.1	6435.2	6481.7	6452.7
G1.0	6637.9	6647.4	6629.2	6623.5	6588.6	6568.0	6507.1	6486.6	6407.7	6383.0
G2.0	6293.6	6331.8	6268.3	6293.0	6197.2	6213.2	6084.6	6044.9	5920.6	5868.3
G3.0	5487.3	5585.5	5488.6	5527.5	5394.5	5388.4	5216.0	5213.8	5063.6	5002.0
G4.0	4591.9	4652.9	4545.5	4585.0	4443.9	4480.5	4303.2	4303.6	4111.3	4096.1
G5.0	3635.9	3734.0	3627.4	3660.5	3521.4	3518.7	3350.6	3357.0	3180.9	3174.4
G6.0	2731.0	2779.8	2679.9	2708.9	2619.5	2618.7	2472.2	2483.0	2333.3	2300.7
G7.0	2039.0	2077.7	1990.1	2011.7	1907.1	1905.9	1815.2	1797.3	1678.1	1680.7
G8.0	1416.7	1489.7	1395.8	1434.1	1328.4	1370.2	1236.5	1286.3	1156.2	1197.5
G9.0	1015.9	1032.1	979.8	988.1	926.6	938.7	873.6	864.7	818.0	806.6
G10.0	716.5	726.4	700.7	702.6	661.1	655.9	614.3	616.1	586.5	577.1
G11.0	506.5	510.1	486.7	492.9	461.5	464.6	437.8	437.5	413.9	412.2
G12.0	373.0	379.2	364.8	362.3	346.9	345.1	331.1	326.0	310.3	309.6
G13.0	284.0	287.1	277.4	278.9	266.8	268.0	256.4	254.9	243.1	243.1
G14.0	221.1	223.2	216.4	215.3	210.9	209.4	201.2	200.1	190.9	191.5
G15.0	180.9	181.2	178.8	176.8	173.6	173.2	167.3	166.1	159.4	158.9
G16.0	150.4	153.4	148.5	148.0	145.4	146.1	140.5	140.3	134.3	135.0
G17.0	130.3	130.3	127.5	126.0	124.6	124.6	121.6	120.4	116.9	116.1
G18.0	113.4	113.2	111.3	111.0	110.0	109.4	107.4	106.0	102.3	102.5
G19.0	99.1	99.2	97.5	96.7	96.7	96.2	93.4	92.7	90.5	90.4
G20.0	88.8	89.0	88.5	87.1	86.6	87.1	84.6	83.5	82.2	81.8
G21.0	80.8	80.6	80.0	78.6	78.9	79.1	76.6	75.9	74.2	75.2
G22.0	73.3	73.1	72.6	71.4	71.4	71.8	70.2	68.7	67.5	67.7
G23.0	66.2	66.5	66.7	65.5	65.1	66.0	63.4	63.3	60.9	60.5
G24.0	59.3	60.0	60.0	59.0	58.3	60.2	58.1	57.6	55.2	55.2
G25.0	53.2	54.2	53.5	53.2	53.2	54.0	52.7	51.7	49.8	48.9
G26.0	48.1	48.4	49.8	50.0	48.4	48.9	47.6	46.4	44.0	44.3
G27.0	43.1	43.8	43.3	44.3	43.5	43.6	43.0	40.9	39.2	39.2
G28.0	38.9	38.9	38.9	40.2	38.5	38.7	38.7	35.3	35.0	35.3
G29.0	33.6	34.1	35.0	36.7	35.0	34.1	34.1	31.4	31.0	31.5
G30.0	30.4	29.7	30.9	31.5	30.7	30.5	30.9	27.8	26.9	26.9
G31.0	27.1	27.3	28.1	28.5	27.3	27.6	27.6	25.6	23.9	24.0
G32.0	23.4	25.1	24.9	25.6	24.2	24.9	24.5	22.5	21.3	21.1
G33.0	22.0	22.5	22.7	23.2	21.8	23.2	22.3	20.3	18.4	21.0
G34.0	20.1	19.8	20.1	21.3	19.6	20.3	19.3	18.1	17.0	18.8
G35.0	17.9	18.2	18.6	19.4	18.2	18.8	18.6	16.2	15.0	15.5
G36.0	16.4	16.9	16.7	18.2	16.4	17.7	17.2	16.2	14.8	14.7

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 7)

Unit: cd

G\C	C200.0	C210.0	C220.0	C230.0	C240.0	C250.0	C260.0	C270.0	C280.0	C290.0
G37.0	15.7	15.7	16.9	16.7	16.0	17.0	16.5	15.9	14.0	14.3
G38.0	15.5	15.5	16.5	16.4	15.7	16.2	16.5	15.9	12.6	13.8
G39.0	14.0	14.7	14.7	16.2	14.3	15.7	15.2	14.5	12.4	13.1
G40.0	13.3	13.0	14.1	14.7	13.1	14.8	14.3	13.3	11.4	11.9
G41.0	12.1	12.4	13.1	13.6	12.4	13.8	13.6	12.1	10.4	10.7
G42.0	11.4	11.8	11.4	12.8	11.4	12.8	12.4	10.9	9.4	10.4
G43.0	10.4	10.2	10.9	11.8	10.4	10.9	11.6	10.4	9.9	8.7
G44.0	9.2	9.4	9.4	10.7	9.4	10.1	9.9	9.7	10.1	8.0
G45.0	8.4	8.7	8.5	9.9	8.7	9.4	9.2	8.7	8.7	7.2
G46.0	7.7	7.5	7.2	8.5	7.7	8.9	8.5	7.7	7.5	6.5
G47.0	6.8	6.3	6.7	8.2	7.2	8.0	7.5	6.8	6.7	5.6
G48.0	5.6	4.9	6.1	7.0	6.7	6.8	7.0	7.0	6.1	4.3
G49.0	5.1	4.9	5.5	6.5	5.8	6.7	6.1	6.0	5.8	3.9
G50.0	4.8	3.9	4.9	6.3	5.6	5.6	6.0	5.1	4.6	3.4
G51.0	4.4	2.9	4.4	5.3	5.3	4.9	5.5	5.5	4.3	3.1
G52.0	4.6	2.4	4.4	4.3	4.3	5.1	4.1	4.1	3.8	1.9
G53.0	4.1	3.1	4.1	4.4	3.9	5.3	4.3	3.4	3.8	1.4
G54.0	3.9	2.6	3.2	4.6	4.1	4.6	3.4	4.3	3.9	0.7
G55.0	2.9	2.9	3.2	3.9	3.4	3.1	3.4	2.4	3.2	0.9
G56.0	3.2	1.5	3.6	3.2	2.9	2.9	2.6	2.7	2.6	0.3
G57.0	2.6	0.9	2.7	2.7	2.7	2.0	2.0	1.7	2.2	0.0
G58.0	2.2	2.2	2.0	1.9	2.4	2.6	1.4	1.5	1.9	0.0
G59.0	1.9	2.2	2.0	1.9	1.0	2.2	1.7	1.4	1.7	0.0
G60.0	1.4	1.5	1.4	1.0	1.2	0.7	1.5	1.0	1.9	0.0
G61.0	1.5	1.4	0.2	0.5	0.3	0.9	0.5	0.9	0.9	0.0
G62.0	0.3	0.3	0.0	0.0	0.2	0.7	0.0	0.0	1.0	0.0
G63.0	0.2	0.3	0.0	0.0	0.3	0.0	0.0	0.0	1.0	0.0
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 9)

Unit: cd

G\C	C300.0	C310.0	C320.0	C330.0	C340.0	C350.0	C360.0			
G0.0	6472.3	6462.4	6470.6	6489.0	6472.3	6514.1	6588.4			
G1.0	6294.7	6276.4	6175.7	6185.6	6091.3	6075.3	6089.8			
G2.0	5740.1	5683.1	5545.6	5517.1	5367.4	5365.2	5296.5			
G3.0	4810.9	4788.3	4587.6	4591.0	4422.9	4413.7	4269.0			
G4.0	3909.9	3850.3	3697.1	3657.8	3498.9	3484.7	3376.5			
G5.0	3009.8	3001.6	2829.0	2835.9	2656.7	2679.5	2579.8			
G6.0	2197.6	2165.7	2055.0	2035.3	1916.9	1910.5	1828.1			
G7.0	1572.1	1574.1	1463.4	1475.7	1384.3	1380.3	1294.5			
G8.0	1080.9	1100.3	1006.7	1033.8	938.9	967.7	923.7			
G9.0	766.3	756.1	717.9	714.0	671.4	670.5	632.5			
G10.0	544.2	536.0	511.8	509.4	482.8	480.3	462.7			
G11.0	392.1	385.3	370.8	368.8	351.4	349.5	338.1			
G12.0	296.8	293.9	281.6	283.0	268.2	268.5	258.1			
G13.0	234.4	229.1	223.9	222.3	213.8	214.3	206.3			
G14.0	186.0	183.8	178.7	178.3	173.0	170.7	165.0			
G15.0	155.1	152.6	150.2	149.2	144.7	143.6	140.5			
G16.0	130.6	131.4	127.3	128.2	123.1	124.3	119.8			
G17.0	114.7	113.4	112.2	111.5	108.1	108.1	106.2			
G18.0	101.4	100.1	98.5	98.2	96.7	96.8	94.1			
G19.0	89.8	88.7	87.8	87.8	86.6	87.1	84.4			
G20.0	81.8	81.0	80.0	80.0	79.3	78.9	76.9			
G21.0	75.0	74.0	72.5	73.0	71.8	70.9	68.9			
G22.0	67.7	66.0	65.3	65.8	64.6	63.3	61.0			
G23.0	60.7	59.3	59.2	60.2	58.1	57.6	54.9			
G24.0	54.0	54.6	53.7	54.2	51.7	51.3	49.4			
G25.0	48.3	48.8	48.8	47.9	46.2	46.0	44.8			
G26.0	43.5	43.8	44.0	43.3	42.1	41.1	39.9			
G27.0	39.0	38.0	38.5	37.8	36.3	36.5	36.1			
G28.0	35.1	33.8	34.3	34.3	32.7	33.2	32.2			
G29.0	31.7	29.5	30.0	31.0	30.0	29.0	29.1			
G30.0	27.5	27.1	26.9	28.1	26.4	25.4	26.3			
G31.0	25.1	23.0	24.0	25.2	24.0	23.9	23.5			
G32.0	22.0	20.1	21.1	22.7	21.1	21.1	21.1			
G33.0	20.6	18.4	19.8	20.8	18.4	18.8	19.6			
G34.0	18.9	16.2	18.6	19.1	17.6	17.2	18.2			
G35.0	17.4	15.0	16.7	17.9	16.2	16.7	16.5			
G36.0	14.3	14.7	17.0	17.2	14.7	16.2	16.0			

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:

Candlepower Table (Continue 10)

Unit: cd

G\C	C300.0	C310.0	C320.0	C330.0	C340.0	C350.0	C360.0			
G37.0	13.6	13.6	16.0	16.0	14.7	15.5	15.5			
G38.0	13.1	12.4	15.5	15.2	13.0	14.7	14.5			
G39.0	12.1	12.1	14.0	13.6	13.0	13.6	13.3			
G40.0	11.1	11.3	13.1	12.8	11.8	12.3	12.6			
G41.0	10.2	10.4	11.8	12.3	10.4	11.3	11.9			
G42.0	9.4	9.9	10.6	11.1	9.6	10.6	10.6			
G43.0	8.2	7.7	9.9	9.9	8.4	8.7	9.6			
G44.0	6.8	7.3	8.5	8.5	7.7	7.3	8.7			
G45.0	6.1	6.8	7.2	6.1	6.7	7.0	8.0			
G46.0	4.9	5.5	6.5	5.1	6.3	6.5	7.2			
G47.0	4.3	4.9	6.5	3.8	4.9	6.1	6.8			
G48.0	4.4	4.4	4.6	3.2	4.3	4.9	5.1			
G49.0	3.8	3.9	4.6	2.6	4.1	4.8	4.6			
G50.0	2.7	3.8	3.9	2.2	3.8	4.3	4.3			
G51.0	2.4	3.2	3.9	2.0	2.9	3.8	3.1			
G52.0	2.0	2.6	3.1	1.5	2.7	3.6	4.3			
G53.0	2.2	2.0	2.7	1.2	2.6	2.7	4.3			
G54.0	2.2	1.5	2.4	0.9	2.6	1.9	3.1			
G55.0	1.9	1.0	1.7	0.3	0.5	1.5	2.7			
G56.0	1.4	0.7	1.5	0.0	1.5	1.2	2.6			
G57.0	1.0	0.7	1.0	0.0	1.0	0.7	2.2			
G58.0	1.0	0.2	0.3	0.0	0.2	0.7	1.4			
G59.0	0.2	0.0	0.0	0.0	0.0	0.0	0.5			
G60.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5			
G61.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5			
G62.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G63.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			

C Plane (°):0.0-360.0: 10.0
 Test Lab: Svet-lab
 Test Type: TYPE C
 Temperature:
 Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
 Test Device: LSG-1700B
 Distance: 9.600 m
 Humidity:
 Inspector:



C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector: