



Report No.:

Test Time: 2021-08-18 18:31

Luminaire Property

Luminaire Manufacturer:

Luminaire Description: RAD-S-CIS-30.3000.24.8

Luminous Length (mm): -165

Luminous Width (mm): -165

Luminous Height (mm): 75

Voltage: 24.0 V

Current: 1.356 A

Power: 32.56 W

Power Factor: 1.000

Photometric Results

CIE Class: Direct

Measurement Flux: 2689.7 lm

Downward Ratio: 100%

Total Rated Lamp Lumens: 2689.7 lm

Efficiency: 100%

Upward Ratio: 0%

Field Angle(C0/C180,C90/C270,C45/C225,C135/315): 22.1, 21.9, 21.9, 21.9

Beam Angle(C0/C180,C90/C270,C45/C225,C135/315): 11.6, 11.6, 11.5, 11.6

Luminaire Efficacy Rating (LER): 82.66

Central Intensity: 46219.76 cd


Max. Intensity: 46219.77 cd

Pos of Max. Intensity: H0 V0


S/MH(C0/C180): 0.20

S/MH(C90/C270): 0.20

Picture Of Luminaire



Luminous Intensity Distribution Curve



— C0-C180 — C90-C270

C Plane (°):0.0-360.0: 10.0

Test Lab: Svet-lab

Test Type: TYPE C

Temperature:

Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0

Test Device: LSG-1700B



Distance: 9.600 m

Humidity:

Inspector:




Luminous Intensity Distribution Curve




C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:

Luminous Intensity Distribution Curve(cd/klm)



Isocandela (rectangle)



Imax (100%): 46220 cd

(10%): 4622 cd	(16%): 7395 cd
(25%): 11555 cd	(40%): 18488 cd
(63%): 29118 cd	(100%): 46220 cd

C Plane (°):0.0-360.0: 10.0

Test Lab: Svet-lab

Test Type: TYPE C

Temperature:

Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0


Test Device: LSG-1700B

Distance: 9.600 m

Humidity:

Inspector:

IsoLux Plot




Mounting Height: 10.0m Max Lux(100%): 462.2 lx

— (1%): 4.6 lx	— (2%): 9.2 lx
— (5%): 23.1 lx	— (10%): 46.2 lx
— (20%): 92.4 lx	— (50%): 231.1 lx
— (100%): 462.2 lx	


C Plane (°):0.0-360.0: 10.0
 Test Lab: Svet-lab
 Test Type: TYPE C
 Temperature:
 Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
 Test Device: LSG-1700B
 Distance: 9.600 m
 Humidity:
 Inspector:

Illuminance at a Distance



Vertical IsoLux Plot




Lowest(m): 1.0m Highest(m): 11.0m Max Lux: 46219.8 lx

— (1%): 462.2 lx	— (2%): 924.4 lx
— (5%): 2311.0 lx	— (10%): 4622.0 lx
— (20%): 9244.0 lx	— (50%): 23109.9 lx
— (100%): 46219.8 lx	



The Average Illuminance Effective Figure




UGR Table

Reflectance:										
Ceiling (cavity)	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
Wall	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
Reference plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
X=2H Y=2H	5.6	6.0	5.8	6.2	6.4	4.8	5.3	5.0	5.4	5.6
3H	5.4	5.9	5.7	6.1	6.3	4.7	5.1	4.9	5.3	5.6
4H	5.4	5.8	5.7	6.0	6.3	4.6	5.0	4.9	5.3	5.5
6H	5.3	5.7	5.6	5.9	6.2	4.5	4.9	4.8	5.2	5.5
8H	5.2	5.6	5.6	5.9	6.2	4.5	4.9	4.8	5.1	5.4
12H	5.2	5.6	5.5	5.9	6.2	4.5	4.8	4.8	5.1	5.4
X=4H Y=2H	5.4	5.8	5.7	6.0	6.3	4.6	5.0	4.9	5.3	5.5
3H	5.2	5.6	5.5	5.9	6.2	4.5	4.8	4.8	5.1	5.4
4H	5.1	5.4	5.5	5.8	6.1	4.4	4.7	4.7	5.0	5.4
6H	5.0	5.3	5.4	5.7	6.1	4.3	4.6	4.7	4.9	5.3
8H	5.0	5.2	5.4	5.6	6.0	4.2	4.5	4.6	4.9	5.3
12H	4.9	5.2	5.3	5.6	6.0	4.2	4.4	4.6	4.8	5.2
X=8H Y=4H	5.0	5.2	5.4	5.6	6.0	4.2	4.5	4.6	4.9	5.3
6H	4.9	5.1	5.3	5.5	6.0	4.1	4.3	4.6	4.7	5.2
8H	4.8	5.0	5.3	5.4	5.9	4.1	4.2	4.5	4.7	5.2
12H	4.8	4.9	5.2	5.4	5.9	4.0	4.2	4.5	4.6	5.1
X=12H Y=4H	4.9	5.2	5.3	5.6	6.0	4.2	4.4	4.6	4.8	5.2
6H	4.8	5.0	5.3	5.4	5.9	4.1	4.2	4.5	4.7	5.2
8H	4.8	4.9	5.2	5.4	5.9	4.0	4.2	4.5	4.6	5.1
Variations with the observer position at spacings:										
S=1.0H	+4.2/-1.\$					+3.9/-1.\$				
S=1.5H	+6.9/-1.\$					+6.7/-1.\$				
S=2.0H	+8.9/-1.\$					+8.7/-1.\$				

Calculate in accordance with CIE Pub.117. The table is revised with 2690lm ($8\log(F/F_0) = 3.4$).

FLUX DISTRIBUTION TABLE BASED ON THE IESNA LUMINAIRE CLASSIFICATION SYSTEM


	ZONE	LUMENS	% LAMP LUMENS
	FORWARD LIGHT	1257	46.7
	FL (0°-30°)	1218	45.3
	FM (30°-60°)	38	1.4
	FH (60°-80°)	0	0.0
	FVH (80°-90°)	0	0.0
	BACK LIGHT	1433	53.3
	BL (0°-30°)	1388	51.6
	BM (30°-60°)	45	1.7
	BH (60°-80°)	0	0.0
	BVH (80°-90°)	0	0.0
	UP LIGHT	0	0.0
	UL (90°-100°)	0	0.0
	UH (100°-180°)	0	0.0
	TRAPPED LIGHT	NA	NA

BUG(Backlight,Uplight,Glare) Rating Base On TM-15-07	
Asymmetrical Luminaire Types (Type I,II,III,IV)	B3 U0 G0
Quadrilateral Symmetrical Luminaire Types (Type V,Area Light)	B3 U0 G0

C Plane (°):0.0-360.0: 10.0
 Test Lab: Svet-lab
 Test Type: TYPE C
 Temperature:
 Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
 Test Device: LSG-1700B
 Distance: 9.600 m
 Humidity:
 Inspector:

LCS Graph



Back Light

Forward Light

Scale= MAX LCS%

Trapped Light:NA,NA



Zonal Lumen

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
0.0-1.0	45440.7	43.5	43.5	1.62	1.62
1.0-2.0	44097.4	126.6	170.1	4.71	6.32
2.0-3.0	41133.2	196.8	366.8	7.32	13.64
3.0-4.0	36623.8	245.2	612.0	9.12	22.75
4.0-5.0	31065.3	267.3	879.3	9.94	32.69
5.0-6.0	24775.8	260.4	1139.7	9.68	42.37
6.0-7.0	18834.9	233.8	1373.5	8.69	51.07
7.0-8.0	13964.4	199.9	1573.4	7.43	58.50
8.0-9.0	10109.0	163.9	1737.2	6.09	64.59
9.0-10.0	7336.0	132.8	1870.0	4.94	69.53
10.0-11.0	5342.8	106.8	1976.8	3.97	73.50
11.0-12.0	3931.3	85.9	2062.7	3.20	76.69
12.0-13.0	2998.6	71.2	2133.9	2.65	79.34
13.0-14.0	2323.0	59.5	2193.4	2.21	81.55
14.0-15.0	1841.3	50.6	2243.9	1.88	83.43
15.0-16.0	1504.5	44.1	2288.0	1.64	85.07
16.0-17.0	1253.1	39.0	2327.1	1.45	86.52
17.0-18.0	1067.8	35.2	2362.3	1.31	87.83
18.0-19.0	918.3	32.0	2394.2	1.19	89.02
19.0-20.0	795.1	29.1	2423.3	1.08	90.10
20.0-21.0	694.9	26.7	2450.0	0.99	91.09
21.0-22.0	607.0	24.4	2474.4	0.91	92.00
22.0-23.0	531.8	22.3	2496.7	0.83	92.83
23.0-24.0	466.1	20.4	2517.1	0.76	93.58
24.0-25.0	407.5	18.5	2535.6	0.69	94.27
25.0-26.0	359.0	16.9	2552.6	0.63	94.90
26.0-27.0	314.4	15.4	2568.0	0.57	95.48
27.0-28.0	274.5	13.9	2581.9	0.52	95.99
28.0-29.0	241.7	12.6	2594.5	0.47	96.46
29.0-30.0	212.9	11.5	2606.0	0.43	96.89
30.0-31.0	189.0	10.5	2616.5	0.39	97.28
31.0-32.0	167.5	9.6	2626.1	0.36	97.64
32.0-33.0	147.4	8.7	2634.8	0.32	97.96
33.0-34.0	130.5	7.9	2642.7	0.29	98.25
34.0-35.0	114.7	7.1	2649.8	0.26	98.52
35.0-36.0	100.7	6.4	2656.2	0.24	98.76

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:




Zonal Lumen (Continue 1)

Gamma [°]	I _{mean} [cd]	Zonal Flux [lm]	Sum Zonal Flux [lm]	Rel Zonal Flux [%]	Sum Rel Zonal Flux [%]
36.0-37.0	88.1	5.7	2662.0	0.21	98.97
37.0-38.0	76.0	5.1	2667.1	0.19	99.16
38.0-39.0	65.5	4.5	2671.5	0.17	99.33
39.0-40.0	55.6	3.9	2675.4	0.14	99.47
40.0-41.0	46.6	3.3	2678.7	0.12	99.59
41.0-42.0	39.3	2.9	2681.6	0.11	99.70
42.0-43.0	31.9	2.4	2684.0	0.09	99.79
43.0-44.0	25.1	1.9	2685.9	0.07	99.86
44.0-45.0	18.9	1.5	2687.3	0.05	99.91
45.0-46.0	12.8	1.0	2688.3	0.04	99.95
46.0-47.0	8.3	0.7	2689.0	0.02	99.97
47.0-48.0	4.6	0.4	2689.3	0.01	99.99
48.0-49.0	2.2	0.2	2689.5	0.01	99.99
49.0-50.0	1.2	0.1	2689.6	0.00	100.00
50.0-51.0	0.5	0.0	2689.7	0.00	100.00
51.0-52.0	0.1	0.0	2689.7	0.00	100.00
52.0-53.0	0.0	0.0	2689.7	0.00	100.00
53.0-54.0	0.0	0.0	2689.7	0.00	100.00
54.0-55.0	0.0	0.0	2689.7	0.00	100.00
55.0-56.0	0.0	0.0	2689.7	0.00	100.00
56.0-57.0	0.0	0.0	2689.7	0.00	100.00
57.0-58.0	0.0	0.0	2689.7	0.00	100.00
58.0-59.0	0.0	0.0	2689.7	0.00	100.00
59.0-60.0	0.0	0.0	2689.7	0.00	100.00
60.0-61.0	0.0	0.0	2689.7	0.00	100.00
61.0-62.0	0.0	0.0	2689.7	0.00	100.00
62.0-63.0	0.0	0.0	2689.7	0.00	100.00
63.0-64.0	0.0	0.0	2689.7	0.00	100.00
64.0-65.0	0.0	0.0	2689.7	0.00	100.00
65.0-66.0	0.0	0.0	2689.7	0.00	100.00
66.0-67.0	0.0	0.0	2689.7	0.00	100.00
67.0-68.0	0.0	0.0	2689.7	0.00	100.00
68.0-69.0	0.0	0.0	2689.7	0.00	100.00
69.0-70.0	0.0	0.0	2689.7	0.00	100.00
70.0-71.0	0.0	0.0	2689.7	0.00	100.00
71.0-72.0	0.0	0.0	2689.7	0.00	100.00

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Zonal Lumen (Continue 2)

[illegible]

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table

Unit: cd

G\C	C0.0	C10.0	C20.0	C30.0	C40.0	C50.0	C60.0	C70.0	C80.0	C90.0
G0.0	46219.8	46155.0	46146.4	46057.8	46040.7	45947.0	45921.4	45805.5	45807.2	45711.7
G1.0	45319.6	45103.0	45201.9	44988.8	45150.8	45009.2	45014.4	44775.7	44854.1	44702.4
G2.0	43043.4	42777.4	42826.9	42612.1	42815.0	42583.1	42792.8	42402.4	42569.4	42175.6
G3.0	38939.6	38353.1	38620.8	38095.6	38598.6	38066.6	38416.2	37868.9	38341.1	37802.4
G4.0	33802.5	32818.8	33357.6	32743.8	33043.8	32713.1	33101.8	32493.1	32755.7	32153.8
G5.0	27598.2	26854.8	27102.1	26478.0	27054.3	26440.5	26815.6	26183.1	26737.2	26116.6
G6.0	20967.6	20263.4	20730.6	20140.7	20664.1	20081.0	20427.1	19850.8	20065.7	19496.2
G7.0	15944.8	15325.9	15479.3	14944.0	15363.4	14848.5	15128.1	14614.9	15025.8	14302.9
G8.0	11735.2	10881.1	11481.2	10693.5	11157.3	10555.4	11092.5	10359.3	10836.7	10127.5
G9.0	8427.6	8003.1	8086.6	7711.5	7912.7	7556.4	7703.0	7384.2	7633.1	7333.0
G10.0	6134.5	5911.1	5958.8	5682.6	5727.0	5536.0	5619.5	5374.0	5542.8	5256.4
G11.0	4448.2	4230.0	4255.6	4137.9	4151.6	4004.9	4042.5	3812.3	3907.8	3781.6
G12.0	3372.4	3225.8	3227.5	3120.1	3142.2	3005.8	3012.7	2881.4	2913.8	2833.6
G13.0	2576.2	2487.5	2484.1	2410.8	2410.8	2322.2	2335.8	2211.3	2257.4	2178.9
G14.0	2011.8	1947.1	1940.2	1889.1	1882.3	1824.3	1803.8	1739.1	1764.6	1720.3
G15.0	1626.5	1580.5	1580.5	1537.9	1525.9	1485.0	1483.3	1420.2	1439.0	1416.8
G16.0	1336.7	1304.3	1299.2	1278.7	1251.4	1234.4	1210.5	1171.3	1196.9	1152.6
G17.0	1133.8	1103.1	1113.3	1094.6	1063.9	1062.2	1040.0	1004.2	1019.6	1000.8
G18.0	976.9	949.7	961.6	951.4	924.1	908.7	898.5	872.9	888.3	871.2
G19.0	842.3	821.8	832.0	816.7	797.9	794.5	777.5	750.2	762.1	746.8
G20.0	726.3	709.3	722.9	721.2	699.0	685.4	678.6	658.1	676.9	654.7
G21.0	637.7	615.5	636.0	624.0	612.1	603.6	591.6	569.5	584.8	571.2
G22.0	552.4	538.8	560.9	554.1	528.5	528.5	518.3	492.7	509.8	501.3
G23.0	484.2	485.9	489.3	491.0	468.9	460.3	450.1	439.9	451.8	446.7
G24.0	424.5	417.7	422.8	426.2	410.9	404.1	390.4	373.4	392.1	392.1
G25.0	373.4	368.3	378.5	378.5	351.2	356.3	342.7	334.2	339.3	335.9
G26.0	325.6	327.4	327.4	330.8	318.8	320.5	296.7	293.3	306.9	296.7
G27.0	277.9	284.7	284.7	289.8	274.5	274.5	264.3	255.7	254.0	262.6
G28.0	247.2	250.6	255.7	260.9	242.1	240.4	228.5	223.4	226.8	225.1
G29.0	216.5	221.6	225.1	231.9	214.8	209.7	206.3	194.4	202.9	196.1
G30.0	197.8	202.9	202.9	208.0	180.7	191.0	177.3	175.6	173.9	170.5
G31.0	173.9	184.1	185.8	180.7	165.4	165.4	162.0	156.9	150.0	155.1
G32.0	150.0	156.9	168.8	165.4	141.5	144.9	139.8	131.3	133.0	138.1
G33.0	141.5	146.6	143.2	148.3	124.5	133.0	115.9	114.2	115.9	131.3
G34.0	121.1	127.9	124.5	138.1	112.5	117.6	100.6	100.6	102.3	112.5
G35.0	105.7	112.5	112.5	126.2	93.8	102.3	86.9	92.1	92.1	100.6
G36.0	97.2	97.2	98.9	114.2	81.8	88.7	76.7	80.1	78.4	83.5

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 1)

Unit: cd

G\C	C0.0	C10.0	C20.0	C30.0	C40.0	C50.0	C60.0	C70.0	C80.0	C90.0
G37.0	80.1	88.7	92.1	104.0	75.0	76.7	64.8	71.6	71.6	78.4
G38.0	68.2	80.1	69.9	90.4	58.0	66.5	58.0	59.7	61.4	69.9
G39.0	59.7	63.1	66.5	80.1	49.4	56.3	40.9	49.4	52.8	63.1
G40.0	46.0	59.7	42.6	69.9	42.6	49.4	30.7	37.5	44.3	54.6
G41.0	30.7	51.2	35.8	64.8	30.7	35.8	23.9	25.6	39.2	42.6
G42.0	25.6	46.0	23.9	58.0	27.3	35.8	22.2	22.2	22.2	35.8
G43.0	22.2	40.9	23.9	51.2	18.8	23.9	11.9	13.6	20.5	25.6
G44.0	13.6	35.8	20.5	46.0	10.2	20.5	6.8	10.2	13.6	22.2
G45.0	5.1	30.7	10.2	35.8	8.5	8.5	3.4	1.7	6.8	6.8
G46.0	3.4	22.2	1.7	34.1	0.0	3.4	0.0	0.0	0.0	1.7
G47.0	0.0	20.5	0.0	23.9	0.0	0.0	0.0	0.0	0.0	0.0
G48.0	0.0	13.6	0.0	18.8	0.0	0.0	0.0	0.0	0.0	0.0
G49.0	0.0	6.8	0.0	11.9	0.0	0.0	0.0	0.0	0.0	0.0
G50.0	0.0	1.7	0.0	11.9	0.0	0.0	0.0	0.0	0.0	0.0
G51.0	0.0	3.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G52.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G53.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G54.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G55.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G56.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G57.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G58.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G59.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G60.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G61.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G62.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G63.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 3)

Unit: cd

G\C	C100.0	C110.0	C120.0	C130.0	C140.0	C150.0	C160.0	C170.0	C180.0	C190.0
G0.0	45710.0	45611.1	45614.5	45508.8	45505.4	45425.3	45437.2	45363.9	46219.8	46155.0
G1.0	44784.2	44574.5	44652.9	44475.6	44560.8	44443.2	44678.5	44555.7	45783.3	45870.3
G2.0	42387.0	42029.0	42211.4	41935.2	42294.9	41988.1	42482.5	42339.3	43967.5	44214.7
G3.0	38111.0	37638.7	37887.6	37521.1	37836.5	37630.2	38186.0	38249.1	40387.1	40808.2
G4.0	32484.6	31964.6	32220.3	31807.7	32457.3	31973.1	32900.6	32771.0	35524.6	36099.1
G5.0	26445.6	25613.6	26154.1	25485.7	26126.8	25939.3	26612.7	26510.4	29308.3	29980.0
G6.0	19770.7	19286.5	19770.7	19179.1	19779.2	19356.4	20236.2	20142.4	22670.9	23342.6
G7.0	14771.8	14130.7	14550.1	14050.6	14572.3	14435.9	14986.6	14896.2	17041.1	17634.4
G8.0	10632.1	9979.1	10628.7	9928.0	10662.8	10091.7	11024.3	10637.3	12337.1	12988.4
G9.0	7479.7	7118.2	7362.0	7206.9	7408.0	7350.1	7825.8	7667.2	9102.8	9334.7
G10.0	5379.1	5205.2	5389.4	5213.8	5425.2	5411.5	5677.5	5648.5	6639.1	6886.3
G11.0	3868.6	3723.6	3858.3	3800.4	3943.6	3882.2	4109.0	4105.5	4816.5	5005.8
G12.0	2893.3	2847.3	2947.9	2886.5	2971.8	2939.4	3130.3	3101.3	3607.7	3756.0
G13.0	2252.3	2202.8	2305.1	2243.7	2322.2	2306.8	2410.8	2398.9	2801.3	2918.9
G14.0	1762.9	1740.8	1790.2	1773.2	1803.8	1800.4	1895.9	1889.1	2148.3	2250.6
G15.0	1432.2	1423.6	1473.1	1464.6	1486.7	1488.4	1543.0	1544.7	1751.0	1827.7
G16.0	1193.5	1178.1	1202.0	1195.2	1213.9	1220.8	1278.7	1275.3	1428.8	1510.6
G17.0	1005.9	1016.2	1034.9	1023.0	1036.6	1036.6	1082.7	1086.1	1212.2	1254.8
G18.0	874.6	871.2	890.0	888.3	895.1	900.2	939.4	932.6	1033.2	1089.5
G19.0	751.9	753.6	770.6	770.6	765.5	768.9	806.5	799.6	893.4	929.2
G20.0	659.8	658.1	671.8	682.0	675.2	678.6	704.2	697.3	767.2	806.5
G21.0	583.1	576.3	595.0	584.8	588.2	588.2	620.6	596.7	676.9	712.7
G22.0	504.7	501.3	520.0	514.9	514.9	521.7	532.0	528.5	588.2	625.7
G23.0	448.4	448.4	456.9	460.3	450.1	455.2	472.3	463.8	514.9	552.4
G24.0	388.7	393.9	399.0	397.3	387.0	393.9	407.5	397.3	445.0	485.9
G25.0	344.4	351.2	347.8	356.3	334.2	346.1	359.8	346.1	395.5	424.5
G26.0	308.6	315.4	315.4	315.4	295.0	301.8	325.6	300.1	344.4	376.8
G27.0	262.6	269.4	269.4	267.7	260.9	266.0	283.0	259.1	295.0	327.4
G28.0	235.3	242.1	233.6	237.0	219.9	228.5	243.8	226.8	262.6	293.3
G29.0	204.6	206.3	208.0	213.1	197.8	202.9	213.1	204.6	230.2	262.6
G30.0	185.8	187.6	187.6	191.0	177.3	184.1	189.3	180.7	194.4	235.3
G31.0	165.4	170.5	168.8	173.9	156.9	165.4	167.1	158.6	177.3	206.3
G32.0	143.2	150.0	148.3	151.7	134.7	143.2	151.7	139.8	150.0	177.3
G33.0	127.9	133.0	129.6	134.7	121.1	121.1	129.6	115.9	136.4	158.6
G34.0	117.6	115.9	107.4	117.6	98.9	110.8	117.6	107.4	124.5	134.7
G35.0	109.1	104.0	88.7	104.0	83.5	92.1	97.2	86.9	114.2	126.2
G36.0	100.6	88.7	85.3	90.4	69.9	78.4	86.9	78.4	92.1	114.2

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:




Candlepower Table (Continue 4)

Unit: cd

G\C	C100.0	C110.0	C120.0	C130.0	C140.0	C150.0	C160.0	C170.0	C180.0	C190.0
G37.0	86.9	78.4	69.9	75.0	63.1	69.9	80.1	66.5	78.4	98.9
G38.0	78.4	68.2	61.4	63.1	52.8	47.7	61.4	56.3	68.2	83.5
G39.0	71.6	58.0	47.7	61.4	47.7	42.6	59.7	47.7	58.0	75.0
G40.0	58.0	52.8	40.9	51.2	40.9	32.4	46.0	34.1	51.2	64.8
G41.0	47.7	44.3	34.1	46.0	30.7	22.2	40.9	29.0	40.9	58.0
G42.0	44.3	35.8	30.7	44.3	27.3	18.8	34.1	22.2	35.8	44.3
G43.0	30.7	23.9	27.3	32.4	13.6	13.6	25.6	17.0	22.2	32.4
G44.0	22.2	18.8	17.0	30.7	18.8	5.1	17.0	11.9	22.2	27.3
G45.0	18.8	11.9	10.2	22.2	6.8	5.1	15.3	11.9	17.0	29.0
G46.0	0.0	5.1	8.5	11.9	5.1	0.0	10.2	3.4	6.8	20.5
G47.0	0.0	3.4	6.8	8.5	1.7	0.0	6.8	0.0	3.4	15.3
G48.0	0.0	0.0	0.0	1.7	0.0	0.0	3.4	0.0	0.0	6.8
G49.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	3.4
G50.0	0.0	0.0	0.0	1.7	0.0	0.0	0.0	0.0	0.0	0.0
G51.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G52.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G53.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G54.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G55.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G56.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G57.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G58.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G59.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G60.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G61.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G62.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G63.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 6)

Unit: cd

G\C	C200.0	C210.0	C220.0	C230.0	C240.0	C250.0	C260.0	C270.0	C280.0	C290.0
G0.0	46146.4	46057.8	46040.7	45947.0	45921.4	45805.5	45807.2	45711.7	45710.0	45611.1
G1.0	45727.0	45779.9	45558.2	45604.3	45440.6	45493.4	45336.6	45403.1	45266.7	45319.6
G2.0	44066.4	44132.9	43851.6	43919.8	43643.6	43851.6	43677.7	43872.0	43638.5	43812.4
G3.0	40424.6	40709.3	40114.3	40458.7	40090.4	40494.5	40075.1	40467.2	40131.4	40434.8
G4.0	35604.7	35751.3	35262.0	35493.9	35072.7	35674.6	35410.3	35954.2	35565.5	35991.7
G5.0	29427.6	29939.1	29110.5	29703.8	29229.8	29952.7	29649.3	30327.8	29611.8	30436.9
G6.0	22769.7	23027.2	22510.6	22843.1	22365.7	23076.6	22768.0	23463.7	23049.4	23654.6
G7.0	17129.7	17605.4	16921.7	17458.8	17041.1	17663.4	17390.6	18023.1	17651.4	18203.9
G8.0	12420.6	12973.0	12262.1	12870.7	12381.4	13046.4	12494.0	13351.5	12703.7	13477.7
G9.0	9186.3	9326.1	9073.8	9273.3	9067.0	9428.4	9295.4	9656.9	9433.5	9728.5
G10.0	6710.7	6908.5	6654.5	6886.3	6748.2	7004.0	6913.6	7075.6	6903.4	7096.0
G11.0	4898.4	4973.4	4881.3	4959.7	4877.9	5033.0	4973.4	5133.6	5019.4	5152.4
G12.0	3696.4	3802.1	3692.9	3793.5	3728.8	3824.2	3771.4	3832.8	3757.7	3904.4
G13.0	2842.2	2959.8	2884.8	2956.4	2869.4	2966.6	2891.6	2959.8	2908.7	2987.1
G14.0	2221.6	2289.8	2231.8	2282.9	2231.8	2267.6	2218.1	2289.8	2262.5	2310.2
G15.0	1810.7	1868.6	1815.8	1848.2	1790.2	1837.9	1802.1	1846.5	1819.2	1851.6
G16.0	1478.2	1536.2	1481.6	1527.6	1466.3	1508.9	1476.5	1531.1	1483.3	1536.2
G17.0	1256.6	1282.1	1253.2	1277.0	1236.1	1258.3	1246.3	1265.1	1254.8	1282.1
G18.0	1074.1	1098.0	1074.1	1094.6	1067.3	1070.7	1062.2	1087.8	1069.0	1094.6
G19.0	910.5	944.5	925.8	937.7	901.9	920.7	920.7	922.4	919.0	932.6
G20.0	806.5	830.3	801.3	816.7	792.8	803.0	803.0	799.6	803.0	811.6
G21.0	704.2	726.3	705.8	721.2	695.6	709.3	699.0	693.9	705.8	717.8
G22.0	612.1	632.5	620.6	620.6	605.3	617.2	612.1	607.0	613.8	618.9
G23.0	538.8	552.4	538.8	550.7	526.8	537.1	543.9	532.0	547.3	545.6
G24.0	472.3	491.0	477.4	484.2	468.9	474.0	467.2	465.5	465.5	479.1
G25.0	412.6	431.4	424.5	427.9	414.3	410.9	405.8	404.1	421.1	417.7
G26.0	370.0	383.6	373.4	373.4	366.6	364.9	361.5	354.6	371.7	366.6
G27.0	323.9	330.8	322.2	327.4	322.2	320.5	308.6	301.8	320.5	317.1
G28.0	286.4	293.3	284.7	286.4	279.6	277.9	274.5	267.7	277.9	283.0
G29.0	260.9	264.3	254.0	248.9	257.5	242.1	243.8	226.8	228.5	250.6
G30.0	228.5	233.6	219.9	214.8	225.1	208.0	204.6	192.7	199.5	219.9
G31.0	202.9	208.0	196.1	197.8	199.5	187.6	185.8	175.6	177.3	199.5
G32.0	175.6	189.3	180.7	175.6	170.5	158.6	165.4	155.1	150.0	182.4
G33.0	163.7	165.4	158.6	151.7	153.4	138.1	141.5	134.7	136.4	162.0
G34.0	141.5	144.9	139.8	136.4	136.4	117.6	124.5	119.3	117.6	138.1
G35.0	115.9	133.0	122.8	117.6	117.6	102.3	110.8	102.3	104.0	126.2
G36.0	109.1	115.9	110.8	105.7	104.0	88.7	98.9	85.3	90.4	110.8

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 7)

Unit: cd

G\C	C200.0	C210.0	C220.0	C230.0	C240.0	C250.0	C260.0	C270.0	C280.0	C290.0
G37.0	86.9	100.6	100.6	88.7	93.8	76.7	86.9	75.0	75.0	93.8
G38.0	69.9	88.7	86.9	78.4	85.3	69.9	71.6	71.6	66.5	83.5
G39.0	66.5	85.3	76.7	68.2	75.0	59.7	58.0	59.7	59.7	75.0
G40.0	51.2	59.7	63.1	59.7	61.4	42.6	52.8	58.0	47.7	64.8
G41.0	54.6	56.3	54.6	54.6	51.2	40.9	44.3	58.0	44.3	58.0
G42.0	40.9	49.4	51.2	39.2	46.0	30.7	35.8	49.4	29.0	47.7
G43.0	35.8	40.9	42.6	35.8	42.6	30.7	27.3	35.8	20.5	42.6
G44.0	30.7	35.8	30.7	23.9	34.1	25.6	20.5	29.0	15.3	30.7
G45.0	27.3	34.1	22.2	25.6	13.6	17.0	13.6	23.9	13.6	29.0
G46.0	23.9	29.0	22.2	23.9	10.2	15.3	0.0	17.0	3.4	13.6
G47.0	17.0	17.0	17.0	13.6	11.9	5.1	0.0	10.2	1.7	17.0
G48.0	5.1	11.9	10.2	5.1	6.8	0.0	0.0	5.1	0.0	5.1
G49.0	1.7	11.9	5.1	0.0	0.0	0.0	0.0	1.7	0.0	6.8
G50.0	0.0	6.8	0.0	0.0	1.7	0.0	0.0	0.0	0.0	0.0
G51.0	0.0	1.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G52.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G53.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G54.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G55.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G56.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G57.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G58.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G59.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G60.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G61.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G62.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G63.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 9)

Unit: cd

G\C	C300.0	C310.0	C320.0	C330.0	C340.0	C350.0	C360.0			
G0.0	45614.5	45508.8	45505.4	45425.3	45437.2	45363.9	46219.8			
G1.0	45212.1	45217.3	45065.5	45075.7	44912.1	44842.2	45319.6			
G2.0	43619.7	43720.3	43340.1	43508.9	43075.8	43080.9	43043.4			
G3.0	40155.2	40334.2	39925.1	40056.3	39531.2	39567.0	38939.6			
G4.0	35662.6	35928.6	35154.6	35555.2	34643.1	34670.4	33802.5			
G5.0	29787.4	30140.3	29555.5	29744.7	28945.1	28996.3	27598.2			
G6.0	23274.4	23695.5	23097.1	23334.1	22261.7	22331.6	20967.6			
G7.0	17637.8	18256.7	17494.6	17717.9	17022.3	17100.8	15944.8			
G8.0	12843.5	13510.1	12705.4	13256.1	12352.4	12589.4	11735.2			
G9.0	9380.7	9709.8	9242.6	9370.5	8981.7	9017.5	8427.6			
G10.0	6957.9	7070.5	6821.5	6900.0	6615.3	6528.3	6134.5			
G11.0	5067.1	5123.4	4891.5	4990.4	4715.9	4692.0	4448.2			
G12.0	3807.2	3831.1	3715.1	3715.1	3565.1	3529.3	3372.4			
G13.0	2954.7	2961.5	2838.8	2872.9	2722.8	2697.3	2576.2			
G14.0	2269.3	2293.2	2192.6	2197.7	2114.1	2090.3	2011.8			
G15.0	1837.9	1831.1	1776.6	1778.3	1705.0	1681.1	1626.5			
G16.0	1498.7	1510.6	1447.5	1478.2	1396.4	1401.5	1336.7			
G17.0	1266.8	1242.9	1212.2	1222.5	1183.2	1164.5	1133.8			
G18.0	1079.2	1069.0	1038.3	1052.0	1007.6	999.1	976.9			
G19.0	937.7	915.6	888.3	908.7	867.8	859.3	842.3			
G20.0	811.6	796.2	770.6	791.1	757.0	755.3	726.3			
G21.0	716.1	692.2	676.9	695.6	659.8	664.9	637.7			
G22.0	627.4	600.2	581.4	600.2	569.5	574.6	552.4			
G23.0	550.7	530.2	506.4	525.1	506.4	514.9	484.2			
G24.0	477.4	463.8	441.6	462.0	436.5	445.0	424.5			
G25.0	417.7	400.7	385.3	399.0	388.7	393.9	373.4			
G26.0	370.0	349.5	337.6	359.8	341.0	339.3	325.6			
G27.0	329.1	301.8	293.3	310.3	301.8	296.7	277.9			
G28.0	295.0	266.0	252.3	277.9	264.3	260.9	247.2			
G29.0	252.3	231.9	226.8	245.5	228.5	230.2	216.5			
G30.0	231.9	201.2	197.8	206.3	196.1	199.5	197.8			
G31.0	206.3	182.4	173.9	187.6	175.6	189.3	173.9			
G32.0	177.3	160.3	148.3	155.1	156.9	163.7	150.0			
G33.0	165.4	139.8	127.9	148.3	133.0	146.6	141.5			
G34.0	148.3	127.9	107.4	131.3	133.0	131.3	121.1			
G35.0	129.6	104.0	98.9	109.1	121.1	107.4	105.7			
G36.0	121.1	88.7	83.5	104.0	98.9	97.2	97.2			

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



Candlepower Table (Continue 10)

Unit: cd

G\C	C300.0	C310.0	C320.0	C330.0	C340.0	C350.0	C360.0			
G37.0	97.2	76.7	63.1	90.4	88.7	86.9	80.1			
G38.0	90.4	66.5	54.6	68.2	76.7	68.2	68.2			
G39.0	83.5	49.4	42.6	56.3	64.8	63.1	59.7			
G40.0	66.5	42.6	32.4	49.4	54.6	52.8	46.0			
G41.0	61.4	29.0	25.6	40.9	51.2	46.0	30.7			
G42.0	54.6	20.5	20.5	34.1	40.9	40.9	25.6			
G43.0	40.9	15.3	13.6	23.9	37.5	32.4	22.2			
G44.0	35.8	10.2	6.8	23.9	32.4	23.9	13.6			
G45.0	22.2	6.8	0.0	15.3	18.8	11.9	5.1			
G46.0	23.9	0.0	0.0	5.1	17.0	17.0	3.4			
G47.0	10.2	0.0	0.0	1.7	10.2	11.9	0.0			
G48.0	3.4	0.0	0.0	0.0	1.7	0.0	0.0			
G49.0	8.5	0.0	0.0	0.0	0.0	0.0	0.0			
G50.0	6.8	0.0	0.0	0.0	0.0	0.0	0.0			
G51.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G52.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G53.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G54.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G55.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G56.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G57.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G58.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G59.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G60.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G61.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G62.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G63.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G64.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G65.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G66.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G67.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G68.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G69.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G70.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G71.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G72.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
G73.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			

C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector:



C Plane (°):0.0-360.0: 10.0
Test Lab: Svet-lab
Test Type: TYPE C
Temperature:
Operator: Svet-lab

Gamma Plane (°):0.0-90.0:1.0
Test Device: LSG-1700B
Distance: 9.600 m
Humidity:
Inspector: